



# SOUTH DAVIS METRO FIRE AGENCY

## PEER REVIEW FOR FIRE PROTECTION SYSTEMS

In accordance with Section 104.7.2 of the International Fire Code, South Davis Metro will require a “technical opinion and report” (peer review) of all plans for the installation and/or modification of an automatic fire protection system, installation and/or modification of fire alarm and detection systems and related equipment, fire pumps and related fuel tanks, jockey pumps, controllers and related equipment, installation, modification, or removal from service of a standpipe system.

### **Exceptions to required peer reviews:**

- 1- Installation of fire hydrants and underground fire protection supply lines.
- 2- Pre-engineered kitchen hood suppression systems.
- 3- Installation or relocation of less than 10 sprinkler heads.
- 4- Installation or relocation of less than 10 alarm/notification appliances.

The following individuals/companies have been approved by the South Davis Metro Fire as design professionals from whom third-party plan reviews will be accepted. In addition to these individuals, any individual meeting one of the following requirements will be considered an acceptable third-party plans examiner. Credentials must be submitted and reviewed by the South Davis Metro Fire Fire Marshal prior to approval.

### **Third Party Plans Examiner Qualification Requirements:**

1. Licensed Professional Engineer (PE)
2. Licensed Fire Protection Engineer (FPE)
3. Bachelor's Degree or Higher in Fire Protection Engineering
4. NICET Level III Certification in the Specific Field of Review

#### **Protection Consultants Inc.**

##### ***Bob Goodloe***

1199 S. Main St #101  
Centerville, Utah 84014  
Office: 801-295-6070  
Fax: 801-677-6070  
Email: [bob@pciut.com](mailto:bob@pciut.com)

#### **West Coast Code Consultants, Inc.**

908 West Gordon Avenue – Suite #3  
Layton, UT 84041  
Office: 385-237-3722  
Submittals: [permitdeskutah@wc-3.com](mailto:permitdeskutah@wc-3.com)

#### **Craig Blue, PE Inc.**

##### ***Craig Blue, P.E.***

1971 West 3300 South #A  
West Valley City, Utah 84119  
Office: 801-886-3473  
Email: [craig@cbluepe.com](mailto:craig@cbluepe.com)